



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: **SAA190960**

Certificate Holder: KATEK Memmingen GmbH
Mammostraße 1,
87700 Memmingen
Germany

Class Description: Non-Prescribed
Product Description: PV Inverter
Trade Name: Steca Elektronik GmbH; KATEK Memmingen GmbH;
Model No.: StecaGrid 4611_2
Markings: Input: Max 750Vdc, MPP Voltage: 150-600Vdc,
Max 2x13A, Isc: 15A

Standard: Output: 230V~ 50Hz, Max 20A, 4600VA
IP65, Class II

Conditions: IEC 62109-1 Ed 1.0
IEC 62109-2 Ed 1.0
AS/NZS 4777.2:2015
Nil

Certification Mark: RCM and SAA190960

Date First Registered: 29 April 2019
Date of Expiry: 29 April 2024

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 31-01-20 190960/1a
Reissued under RECS scheme



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA190960

Date of Issue: 29 April 2019

Class Description: Non-Prescribed
Product Description: PV Inverter

Additional Models	Trade Name	Rating
StecaGrid 3611_2	Steca Elektronik GmbH	Input: Max 750Vdc, MPP range: 150-600Vdc, Isc: 2x13Adc Max Output: 230V~ 50Hz Max 16A, 3680VA
StecaGrid 3011_2	Steca Elektronik GmbH	Input: Max 750Vdc, MPP range: 125-600Vdc, Isc: 2x13Adc Max Output: 230V~ 50Hz Max 14A, 3000VA
StecaGrid 3611	Steca Elektronik GmbH	Input: Max 750Vdc, MPP range: 150-600Vdc, Isc: 13Adc Max Output: 230V~ 50Hz Max 16A, 3680VA
StecaGrid 3011	Steca Elektronik GmbH	Input: Max 750Vdc, MPP range: 125-600Vdc, Isc: 13Adc Max Output: 230V~ 50Hz Max 14A, 3000VA
StecaGrid 2511	Steca Elektronik GmbH	Input: Max 450Vdc, MPP range: 75-360Vdc, Isc: 13Adc Max Output: 230V~ 50Hz Max 14A, 2500VA
StecaGrid 2011	Steca Elektronik GmbH	Input: Max 450Vdc, MPP range: 75-360Vdc, Isc: 13Adc Max Output: 230V~ 50Hz Max 12A, 2000VA
StecaGrid 1511	Steca Elektronik GmbH	Input: Max 450Vdc, MPP range: 75-360Vdc, Isc: 13Adc Max Output: 230V~ 50Hz Max 12A, 1500VA

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 31-01-20 190960/2a
Reissued under RECS scheme

www.jas-anz.org/register



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA190960

Date of Issue: 31 January 2020

Class Description: Non-Prescribed

Product Description: PV Inverter

General Modification:

Use of alternative trade name KATEK Memmingen GmbH.

Use of additional tests for implemented Volt-Var function.

Additional Models	Trade Name	Rating
StecaGrid 5011_2	Steca Elektronik GmbH; KATEK Memmingen GmbH	Input: Max 750Vdc, MPP range: 150-600Vdc, Max: 2x13Adc, Isc: 15A Output: 230V~ 50Hz Max 22A, 5000VA

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 31-01-20 190960/3